

John Stinemire, P.E.
Consulting Engineer
15 Railroad Avenue- Suite 201 Kingston, New York 12401
Telephone (845) 331-8806
Fax (845) 331-4890

September 6, 2018

Mr. Frank Rittie, Sr.
259 Ulster Landing Road
Kingston, NY 12401

RE: Fire Training Facility
259 Ulster Landing Road
Town of Ulster
Ulster County, New York

Dear Mr. Rittie:


On September 4, 2018 I performed an inspection of the Fire training structure located at 259 Ulster Landing Road, Town of Ulster, NY. The subject building consists of a two-story cast-in-place and precast concrete structure used for fire training exercises.

There is one location where the steel exterior stair is not securely mounted to the concrete slab. The existing anchor bolt has become detached from the concrete. A new anchor bolt will need to be installed at this location.

Once the above repair has been made, I hereby certify that the subject fire training building will be structurally sound and safe for live fire training exercises. This building has been inspected for use under NFPA 1403 Live Fire training evolutions.

Should you have any questions or concerns, please feel free to contact me.

Sincerely,



John Stinemire, PE
Consulting Engineer

